

Cable Management

Design and Technical Information
2016





MARLEY NEW ZEALAND

Marley New Zealand manufactures extruded and injection moulded uPVC and Polyethylene products for the New Zealand building, civil infrastructure and rural markets. Marley also export products to the Pacific Islands, South East Asia, Australia and the UK.

Today there are over 200 people in the Marley NZ team with manufacturing taking place on two sites – Auckland in the North Island, which also houses the Head Office, and Christchurch in the South Island.

Aliaxis Group



Marley New Zealand is part of the Aliaxis group, a privately owned business based in Belgium which employs 15,700 people across forty countries and is made up of 100 companies worldwide. Each of these companies manufactures and/or markets plastic products for construction, industrial and public uses. Marley NZ is the largest division of Aliaxis in New Zealand and the largest manufacturer of uPVC pipes and fittings in New Zealand.

Keep New Zealand Green

Marley is committed to conducting its business in a manner that is compatible with the environment with regards to where our products are sourced, manufactured, used and disposed. Marley operates a uPVC recycling program as part of our ISO 14001 environmental management system and is Best Environmental Practice certified for its entire manufactured range of uPVC systems. This allows designers and installers to achieve GreenStar credits when using Marley uPVC systems in commercial buildings.



MAKE IT MARLEY

- Reliable local manufacturer for over 50 years
- Commitment to a sustainable future
- Experienced technical and production teams to ensure quality and rigorous testing
- ISO 9001 and 14001 accreditation
- Complete range of products and systems
- Nationwide distribution network
- 100% Recyclable products
- Best Environmental Practice (BEP) accreditation of uPVC systems.
- Access to international resources through parent company



MARLEY MEANS QUALITY

Marley NZ Ltd is ISO 9001 accredited and holds a Bureau Veritas License for the manufacture of uPVC Conduit and Fittings AS/NZS 2053 Lic No 2297.





CABLE MANAGEMENT

Marley New Zealand Ltd manufacture and supply a wide range of plastic systems for the conveyance and protection of various cable systems. This includes power cables, communication cables and fibre optics.

The systems are manufactured from either uPVC, polyethylene or polypropylene and each come with a range of fittings to facilitate their use in Buildings or Civil projects.

Building

Marley conduit systems are used for power cables and are generally used in exposed situations i.e. external to the wall, although they can also be used within wall or floor cavities and are suitable for casting in concrete. The tested temperature range of -15°C to $+60^{\circ}\text{C}$ enables the conduit to be used in cold areas as well as in roof spaces which may be subjected to elevated temperatures.

Solar conduit is available for use with solar panel installations. It is UV stabilised and rated heavy duty to comply with the conduit requirements of AS/NZS 5033.

Flexible conduits are also available for above ground applications where increased flexibility is required due to a high number of changes in direction.

Trunking systems are available in a range of sizes for use with single cables or a number of cables. They are suitable for alarm wiring, data installations or telephone wiring and provide access to the wiring after installation if required.

Air-con duct systems are used for carrying and protecting cables for heat pump and air conditioner installations.

Civil

Ducting systems are used in buried applications for conveying and protecting various cabling systems. They are available in straight lengths up to 6 metres for the rigid ducts and lengths up to 1000 metres for continuous ducts.

The rigid ducts are manufactured from uPVC and the continuous ducts are polyethylene.

An electrical access pit is also available to provide easy access to the cable joints.

Health, Safety and Environmental

The use of the products referenced in this brochure can expose the installer to a number of hazards due to standard work practices. These may include working at height, working in confined spaces, working in excavated trenches and working with electricity.

It is the responsibility of the installer to ensure that all legal requirements are met; particularly where licensed and/or authorised staff are required for electrical wiring and that the codes of practice of Workplace New Zealand are followed.

Marley offer a take back scheme for any off-cuts or scrap of their pipe systems to reduce the amount of waste going to landfill. To utilise this service please contact our Marley contact centre on 0800 MARLEY (0800 627 539).



PAGE
05

**CONDUIT
SYSTEMS**

BUILDING

PAGE
09

**TRUNKING
SYSTEMS**



PAGE
11

**AIR-CON
DUCT
SYSTEMS**



OUR RANGE OF SYSTEMS

PAGE
17


TECHNICAL
INFORMATION

CIVIL



PAGE
15

DUCT
SYSTEMS



PAGE
13

ACCESS
PITS



CONDUIT SYSTEMS

RIGID CONDUIT



**Multi
purpose**

MEDIUM DUTY

The most economical and versatile option in our range. This rigid conduit offers medium duty protection for your everyday electrical installations.

SUITABLE FOR • Surface wiring • Residential • Commercial



UV protection

SOLAR

Solar conduit is the perfect outdoor solution. This rigid conduit provides high UV resistance, heavy duty mechanical protection and meets the conduit requirements of standard AS/NZS 5033 for photovoltaic system installations.

SUITABLE FOR • Solar panel systems • Outdoor



**Mechanical
protection**

HEAVY DUTY

No need for cable cover when installing heavy duty conduit underground. This rigid conduit meets the underground wiring standard by providing high impact and compression protection for your cables.

Meets Category A wiring standard AS/NZS 3000

SUITABLE FOR • Underground burial • Industrial applications



FITTINGS

Marley offer a full range of heavy duty conduit fittings in both grey and orange to suit your installation needs:

Joiners, junction boxes, bends, elbows, inspection bends, clips, enclosure boxes* and more.

*See page 22 for more information

Marley offers the largest range of conduit systems manufactured in New Zealand to suit your electrical installation needs. Marley conduit achieves superior performance in our harsh climate. All products manufactured by Marley are BEP-certified, 100% recyclable and tested to meet AS/NZS 2053.

PRODUCT SNAPSHOT

For a quick guide on key properties for rigid conduit check out our product snapshot. For more detailed technical information please see page 17.



MEDIUM DUTY

SOLAR

HEAVY DUTY


	MEDIUM DUTY	SOLAR	HEAVY DUTY
COLOURS AVAILABLE	Grey Orange	Grey	Orange
MATERIAL	uPVC	uPVC	uPVC
SIZES AVAILABLE	20 - 50mm	20 - 50mm	20 - 50mm
DUTY RATING**	Medium duty	Heavy duty	Heavy duty
COMPRESSION RESISTANCE**	Medium	High	High
IMPACT RESISTANCE**	Medium	High	High
UV RESISTANT**	Yes – grey No – orange	Yes	No
TEMPERATURE RANGE**	-15°C to +60°C	-15°C to +60°C	-15°C to +60°C
COMPLY WITH AS/NZS STANDARD	2053	2053	2053
BEP CERTIFIED	Yes	Yes	Yes
MARLEY SOLVENT NEEDED TO JOIN	Yes	Yes	Yes
CHEMICAL RESISTANCE	High*	High*	High*
SUITABLE FITTINGS	Yes	Yes	Yes

* Avoid contact with ketones, esters, aromatic and chlorinated solvents

** As per manufacturing standard AS/NZS 2053

CONDUIT SYSTEMS

FLEXIBLE CONDUIT




Extra Flexible

SUPA

Marley SUPA is a flexible polypropylene conduit which offers increased flexibility and a larger internal bore than standard medium duty uPVC flexible conduit.

SUITABLE FOR • Tight corners • Pumps



All-rounder

EASI

Marley EASI is a versatile flexible conduit for your everyday use. It offers high compression and impact resistance to conceal your cables in and around those difficult corners.

SUITABLE FOR • Surface wiring • Commercial



UV protection

SOLA

Marley SOLA is a flexible conduit which is perfect for outdoor use. It is UV resistant, provides heavy duty mechanical protection and meets the conduit requirements of standard AS/NZS 5033 for photovoltaic system installations.

SUITABLE FOR • Solar panel systems • Outdoors



FITTINGS

Marley offers a full range of heavy duty conduit fittings as well as a specific flexible conduit gland.



PRODUCT SNAPSHOT

For a quick guide on key properties for flexible conduit please see the snapshot below. For more detailed technical information please see page 22.



	SUPA	EASI	SOLA
COLOURS AVAILABLE	Grey	Grey	Grey
MATERIAL	Polypropylene	uPVC	uPVC
SIZES AVAILABLE	20, 25mm	20 - 50mm	20 - 32mm
COMPLY WITH AS/NZS STANDARD	2053	2053	2053/5033
DUTY RATING**	Very light duty	Medium duty	Heavy duty
COMPRESSION RESISTANCE**	Low	Medium	High
IMPACT RESISTANCE**	Medium	High	High
LONG-TERM OUTDOOR USE	No	No	Yes
TEMPERATURE RANGE**	-5°C to +60°C	-5°C to +60°C	-5°C to +60°C
BEP CERTIFIED	N/A	Yes	Yes
MARLEY SOLVENT NEEDED TO JOIN	No – use specialist adhesive	Yes	Yes
CHEMICAL RESISTANCE	High*	High*	High*
SUITABLE FITTINGS	Yes	Yes	Yes

* Avoid contact with ketones, esters, aromatic and chlorinated solvents

** As per manufacturing standard AS/NZS 2053

TRUNKING SYSTEMS

MINI & MAXI TRUNKING




Full range

MINI TRUNKING

Mini trunking is suitable for concealing surface cables within new-build and refurbishment applications. It is designed to be aesthetically appealing whilst providing protection for indoor and busy areas. It offers security for keeping your cables concealed, as well as being user-friendly to access the cables in the future. A full range of compatible fittings in each size are available to complete your trunking system.

SUITABLE FOR • Alarm wiring • Data installations • Offices



Large capacity

MAXI TRUNKING

Maxi trunking is an efficient option for concealing and protecting surface cables in applications which require larger cable-carrying capacity. Complete your trunking system with a range of compatible fittings offering quick and easy installation. Maxi trunking is the perfect solution for an unobtrusive and secure cable management system for your electrical installations.

SUITABLE FOR • Industrial • Agricultural • Commercial




FITTINGS

Marley offer a range of compatible fittings for your trunking system – couplings, corners angles, end pieces and side tees.

Marley Trunking and fittings are manufactured from high quality uPVC, to provide cable management solutions for building fit-outs. Made for indoor and outdoor use, it is highly UV resistant and has a range of features for security and accessibility. It is light weight for easy handling and meets the durability requirements of the New Zealand Building Code.

PRODUCT SNAPSHOT

For a quick guide on key properties for trunking please see the snapshot below. For more detailed technical information please see page 25.



MINI TRUNKING

MAXI TRUNKING

COLOURS AVAILABLE	White Brown	Grey
MATERIAL	uPVC	uPVC
SIZES AVAILABLE***	16 - 40mm	50 - 150mm
DUTY RATING*	Light Duty	Heavy Duty
IMPACT RESISTANCE*	Medium	High
NON-FLAMMABLE*	Yes	Yes
UV RESISTANT	White – high Brown – low	Moderate
TEMPERATURE RANGE*	0°C to +60°C	0°C to +60°C
COMPLY WITH AS/NZS STANDARD	4296	4296
CHEMICAL RESISTANCE	High**	High**
SUITABLE FITTINGS	Yes	Yes

* As per manufacturing standard AS/NZS 4296

** Avoid contact with ketones, esters, aromatic and chlorinated solvents

*** Range of depths available

AIR-CON DUCT SYSTEMS

DUCT & FLEXI DUCT



UV protection

AIR-CON DUCT


Designed for New Zealand conditions which call for high impact, strength and both indoor and outdoor use. With a high gloss and colour retention rate, Marley Air-Con duct is an aesthetically pleasing choice for your installation.

- SUITABLE FOR**
- Heat pump installations
 - Air-Conditioning installations

INDEPENDENT WEATHERING TEST RESULTS

In an independent weathering test, various brands of Air-Con duct available in New Zealand were exposed to 1,000 hours of UV light and condensation testing.

Marley Air-Con duct had the least amount of colour change; indicating the **highest resistance to weathering in NZ conditions.**



*Source: 'UV/ Condensation testing of PVC ducting materials' – Felix Research Laboratories, May 2011. Report # 1008079.11

Marley Air-Con Duct offers a high quality system to carry and protect cables for use in heat pump and air-conditioner installations.

PRODUCT SNAPSHOT

For a quick guide on key properties for Air-Con duct systems please see the snapshot below.



AIR-CON DUCT

COLOURS AVAILABLE	Ivory
MATERIAL	uPVC
SIZE AVAILABLE	80mm
IMPACT RESISTANCE	High
UV RESISTANT	Yes
TEMPERATURE RANGE	0°C to +60°C
BEP CERTIFIED	Yes
CHEMICAL RESISTANCE	High*
SUITABLE FITTINGS	Yes

*Avoid contact with ketones, esters, aromatic and chlorinated solvent

ACCESS PITS

EASY ACCESS TO YOUR CABLE JOINTS




1. ANTI-SLIP TRAFFICABLE LID



With watertight rubber gasket

2. ELECTRICAL IDENTIFICATION




Signifies that live cables are enclosed

3. WATERTIGHT HERMETIC SCREWING SYSTEM



For water and dust protection (IP67)

4. VARIOUS SIZED KNOCK-OUT OUTLETS



(sides and bottom)

5. OUTLET



For condensation gathering and discharge

6. PITS HAVE PRE-CUT BASES AND CAN BE STACKED AS RISERS



(hermetic screwing system applies to pit connection)

The Marley electrical access pit is designed to provide quick easy access to your cable jointing. There are various sized knock-outs available, as well as an anti-slip trafficable lid and electrical identification to signify that live cables are enclosed.



High quality

ACCESS PITS

The 250×250mm electrical access pit is non-conductive, resistant to chemicals and high impact resistant with a watertight hermetic screwing/lid system that can be made inaccessible to unauthorised persons.

Should you require one, Marley also offer a range of stormwater access pits and lids.



ACCESS PIT

COLOURS AVAILABLE	Grey
MATERIAL	Polypropylene
IP RATING	67
LOAD RESISTANCE RATING (EN124)	>15KN 1.5tonne
UV RESISTANT	Yes
TEMPERATURE RANGE	-5°C to +50°C
CHEMICAL RESISTANCE	High*
KNOCKOUT SIZES uPVC CONDUIT	40, 50mm
KNOCKOUT SIZES POLYETHYLENE	40, 50, 63, 75mm

*Avoid contact with ketones, esters, aromatic and chlorinated solvent

DUCT SYSTEMS

RIGID & CONTINUOUS DUCT



Durability

RIGID CABLE DUCT

Marley rigid cable duct is manufactured from high quality uPVC, ensuring a long design life to protect power, communication and fibre optic cables. It offers high impact and compression resistance, making it suitable for trenched applications. Marley cable duct is approved by major telecommunication and power authorities.

SUITABLE FOR • Trenched applications • Industrial Sites • Road Side



Flexibility

CONTINUOUS CABLE DUCT

Marley's complete range of polyethylene (PE) continuous duct provides high quality protection for power, communication and fibre optic cable installations. It is designed for use with directional drilling, trench-less and long-run open trench applications. It is also approved by major telecommunication and power authorities.

SUITABLE FOR • Directional drilling • Sub-duct applications



DUCT BENDS

Marley offer a full range of durable uPVC duct bends to suit your installation needs. Various radii, lengths and angles are available.



FITTINGS

Marley provide a full range of Philmac compression and Friatec electrofusion fittings designed for use with polyethylene pipe systems.

Marley cable duct is designed to provide a cost effective solution for underground installations of power and communications cable. Available in larger sizes to carry large and/or multiple cables, with variations of colour and duty ratings to suit all applications.

PRODUCT SNAPSHOT

For a quick guide on key properties for cable duct systems please see the snapshot below. For more detailed technical information please see page 26.



RIGID DUCT

CONTINUOUS DUCT

STOCK COLOURS AVAILABLE**	Orange White Green Salmon	Orange Green
MATERIAL	uPVC	Polyethylene
DUTY RATING***	Very light duty to heavy duty	SDR11 – SDR17
UV RESISTANT	Orange/ Green – No White – Yes	N/A****
TEMPERATURE RANGE	-15°C to +60°C	-15°C to +60°C
BEP CERTIFIED	Yes	N/A
CHEMICAL RESISTANCE	High*	High*
SUITABLE FITTINGS	Yes	Yes

* Avoid contact with ketones, esters, aromatic and chlorinated solvent

** Both rigid and continuous cable duct are available in custom colours. Minimum order quantities and lead time apply

*** Duty rating varies on size and customer requirements, please contact Marley for more information

NB: Marley NZ manufactures a range of communication duct, some of which is designed specifically to meet [Chorus NZ Ltd](#) specifications. Chorus have stated that Chorus branded product may only be sold to a “Chorus approved installer or their approved subcontractor” for use in Chorus NZ projects.

“Unbranded” communications duct is different and may only be used for [non-Chorus NZ](#) communications projects.

RIGID CONDUIT


Marley uPVC conduit and fittings are manufactured from selected PVC resin and impact modifiers. All conduit and fittings are manufactured in accordance with AS/NZS 2053 and carry the Bureau Veritas Licence Number 2297.

Conduit pipe is manufactured in both medium duty and heavy duty and most fittings are rated to heavy duty.

MINIMUM BORE CROSS SECTIONAL AREA (mm²)

NOMINAL SIZE	MEAN OD (mm)	MEDIUM DUTY	HEAVY DUTY
20	19.7 - 20.0	189	165
25	24.7 - 25.0	330	286
32	31.7 - 32.0	568	519
40	39.7 - 40.0	924	850
50	49.7 - 50.0	1486	1379

WALL THICKNESS DIAGRAM EXAMPLE FOR 20MM CONDUIT



Shaded = Cross-sectional area

WEATHER DURABILITY

Marley grey conduit:

Has been developed to meet the durability and weather performance of the New Zealand Building Code B2. Marley Solar conduit is manufactured to meet the requirements of AS/NZS 2053. It is also UV stabilised to meet the conduit suitability requirements for AS/NZS 5033 (Installation and safety requirements for photovoltaic (PV) arrays).

Marley orange conduit:

Uses the same weatherable impact modifier as grey conduit but is not recommended for long term exposure to UV radiation. It does meet the durability requirements of New Zealand Building Code B2 for interior or concealed applications.

RESISTANCE TO BURNING

Marley conduit is classified by AS/NZS 2053 as being a 'non-flame propagating' conduit.

CHEMICAL RESISTANCE

Marley conduits are highly resistant to common corroding agents such as acids and alkalis however they should not be used if likely to be exposed to solvents such as ketones, esters, aromatic and chlorinated hydrocarbons.

TEMPERATURE & EXPANSION

It is recommended that the continuous service temperature does not exceed +60°C or fall below -15°C.

PVC has a relatively high co-efficient of thermal linear expansion and allowance should be made for this. It is recommended that a minimum of 0.6mm movement per metre of length per 10°C change in temperature should be provided for. Long runs require flexible couplings on each standard length, especially if the run is likely to be subjected to wide temperature variations. Failure to provide for this can result in pipes buckling and/or joints breaking. To ensure that the flexible coupling functions correctly, saddles should be fixed not more than 150mm either side of the coupling.

Saddles should not be tightened to the extent as to prevent longitudinal movement of the pipe. Where there are wide temperature variations conduit clips are recommended, with the true expansion being calculated to ensure adequate movement is allowed for.

CHANGE IN TEMPERATURE °C CHANGE IN LENGTH OF 4 METRE LENGTH (mm)

5	1.2
10	2.4
15	3.6
20	4.8
25	6.0
30	7.2
35	8.4
40	9.6

Example 1: Using the above table for an example of a 16 metre run installed in a roof space during winter with an ambient temperature of 20°C and an expected summer ambient temperature of 45°C.

- Allow for 25°C change in temperature.
- Therefore with a 25°C change in temperature, the change in pipe length will be 0.6mm for a 4m length of conduit.
- 6.0mm x 4 lengths of conduit = 24.0mm potential change in length.



IP CLASSIFICATION

The IP rating (or International Protection Rating, also referred to as Ingress Protection Rating) consists of the letters IP followed by two digits. It is defined by IEC 60529 and classifies the degree of protection against the intrusion of a solid object (eg hands, fingers, screwdriver and dust) as the first numeral and protection against water as the second numeral.

PROTECTION AGAINST INGRESS OF SOLID OBJECT		PROTECTION AGAINST HARMFUL INGRESS OF WATER	
REQUIREMENTS		PRESCRIPTIONS	
0	No protection	0	No protection
1	Full penetration of 50mm diameter sphere not allowed. Contact with hazardous parts not permitted	1	Protected against vertically falling drops of water. Limited ingress permitted
2	Full penetration of 12.5mm diameter sphere not allowed. The jointed test finger shall have adequate clearance from hazardous parts	2	Protected against vertically falling drops of water w with enclosure tilted 15° from the vertical. Limited ingress permitted
3	The access probe of 2.5mm diameter shall not penetrate	3	Protected against sprays to 60° from the vertical. Limited ingress permitted
4	The access probe of 1mm diameter shall not penetrate	4	Protected against water splashed from all directions. Limited ingress permitted
5	Limited ingress of dust permitted	5	Protected against jets of water. Limited ingress permitted
6	Totally protected against ingress of dust	6	Protected against strong jets of water. Limited ingress permitted
		7	Protected against the effects of immersion between 15cm and 1m
		8	Protected against long periods of immersion under pressure

As per AS/NZS 3000 Appendix G

IP ratings are often specified for projects and it is important to know that generally any IP rating higher than the one specified will be sufficient for the application. For example, if IP56 is specified you could use IP66, but not IP65 (as the 2nd numeral indicating water protection is too low).

A fully solvent cemented Marley conduit system will provide an IP rating of 67. A full list of the IP ratings for various Marley products or conduit systems are shown in the table to the right.

MARLEY CONDUIT SYSTEM

IP RATING

Fully solvent cemented Marley conduit system	IP67
Marley Access Pit 250mmx250mm (1SD4469)	IP67
Marley circular junction boxes (screwed lid solvent cemented or with 'o'rings)	IP66
Marley Enclosure Boxes (with gaskets)	IP55
Marley circular junction boxes & inspection fittings (screwed lid without solvent cement or 'o' rings)	IP53

EXPANDED POLYSTYRENE INSULATION (EPS)

Marley conduit is suitable for use in contact with EPS insulation and building panels. The phenomenon of plasticizer migration that can occur when PVC insulated cables are in contact with EPS does not occur with Marley uPVC conduit, and the conduit provides a suitable protection between the cable and the EPS.

CABLE CARRYING CAPACITY

The maximum amount of cables that may be enclosed in a conduit shall be an amount which permits installation of the cable without damage, as per NZECP 28 clause 5.6. The number of cables that can be installed in a circular conduit is determined by; the ratios of the cross sectional areas of the enclosure and the cable, as follows:

$$\text{Number of cables} = \frac{\text{Internal cross-section of enclosure}}{\text{Cross-sectional area of cable}} \times \text{space factor}$$

The space factor as per AS/NZS 3000 Appendix C6 recognises the reduction of space available from the circular geometry of the cables and enclosures:

NUMBER OF CABLES	SPACE FACTOR
FOR ONE CABLE IN ENCLOSURE	0.5
FOR TWO CABLES IN ENCLOSURE	0.33
FOR THREE OR MORE CABLES IN ENCLOSURE	0.4

Provided permission by Standards New Zealand under license 001143.

CONDUIT SYSTEMS TECHNICAL INFORMATION

The following tables show examples of maximum number of cables that may be used in conduit by cable type. The number of cables does not consider the effects the grouping of cables may have on temperature rise, voltage drop or current carrying capacity and reference should be made to AS/NZS 3008 for de-rating factors. This maximum number is based on short runs of conduit free of obstructions with minimal changes in direction. Where this is not the case the number of cables should be reduced or the conduit size increased to ensure that the maximum pulling tension is not exceeded.

GUIDE TO THE MAXIMUM NUMBER OF SINGLE-CORE SHEATHED CABLES INSTALLED IN CONDUIT

CABLE SIZE (mm ²)	HEAVY DUTY uPVC CONDUIT					MEDIUM DUTY uPVC CONDUIT				
	20	25	32	40	50	20	25	32	40	50
PVC/PVC V90										
1	5	9	16	26	43	6	10	17	28	45
1.5	4	7	13	21	36	5	8	14	23	38
2.5	3	5	10	16	27	3	6	11	17	28
4	1	3	7	11	19	2	4	7	12	20
6	1	3	6	9	16	1	3	6	10	17
10	1	1	4	6	11	1	2	4	7	11
16	1	1	3	5	8	1	1	3	5	8
XLPE/PVC										
25	0	1	1	3	5					
35	0	1	1	2	4					
50	0	1	1	1	3					
70	0	0	1	1	2					
95	0	0	1	1	1					
120	0	0	0	1	1					
150	0	0	0	1	1					
185	0	0	0	0	1					
240	0	0	0	0	1					
300	0	0	0	0	1					



GUIDE TO THE MAXIMUM NUMBER OF TWO-CORE AND EARTH CABLES INSTALLED IN CONDUIT

CABLE SIZE (mm ²)	HEAVY DUTY uPVC CONDUIT					MEDIUM DUTY uPVC CONDUIT				
	20	25	32	40	50	20	25	32	40	50
PVC/PVC V90										
1.5	1	1	2	4	7	1	1	2	4	7
2.5	0	1	1	3	5	1	1	1	3	6
4	0	1	1	2	4	0	1	1	2	4
6	0	1	1	2	4	0	1	1	2	4

*Continued over page

CABLE SIZE (mm ²)	HEAVY DUTY uPVC CONDUIT					MEDIUM DUTY uPVC CONDUIT				
	20	25	32	40	50	20	25	32	40	50
PVC/PVC V75										
10	0	0	1	1	2	0	0	1	1	2
16	0	0	1	1	1	0	0	1	1	1
25	0	0	0	1	1	0	0	0	1	1
PVC/PVC V90 FLAT										
1	1	2	5	8	14	1	3	5	9	15
1.5	1	2	5	8	13	1	3	5	9	14
2.5	1	1	3	5	9	1	1	3	6	10
4	1	1	2	4	6	1	1	2	4	7
6	0	1	1	3	5	1	1	2	3	6
10	0	1	1	2	4	0	1	1	2	4
16	0	0	1	1	2	0	0	1	1	2

GUIDE TO THE MAXIMUM NUMBER OF FOUR-CORE AND EARTH CABLES INSTALLED IN CONDUIT

CABLE SIZE (mm ²)	HEAVY DUTY uPVC CONDUIT					MEDIUM DUTY uPVC CONDUIT				
	20	25	32	40	50	20	25	32	40	50
PVC/PVC V90										
1.5	0	1	1	3	5	1	1	1	3	5
2.5	0	1	1	2	4	0	1	1	2	4
4	0	0	1	1	3	0	1	1	1	3
6	0	0	1	1	2	0	0	1	1	2
PVC/PVC V75										
10	0	0	0	1	1	0	0	0	1	1
16	0	0	0	1	1	0	0	0	1	1
25	0	0	0	0	1	0	0	0	0	1
35	0	0	0	0	1					
XLPE/PVC										
16	0	0	0	1	1					
25	0	0	0	0	1					
35	0	0	0	0	1					

INSTALLATION OF CONDUIT

The selection of the correct size and classification of conduit for the application is important in order to comply with the appropriate regulations and standards.

Marley conduit and fittings are suitable for use in underground installations and industrial applications where impact resistance is required. They are not recommended where they are likely to be subjected to severe mechanical abuse. In order to comply with AS/NZS 3000 Australian/New Zealand Wiring Rules the following guidelines apply:

Category A: underground wiring systems may use heavy duty conduit without further mechanical protection.

Category B: underground wiring systems may use medium duty conduit with additional mechanical protection. Refer to clause 3.11.4.3 of AS/NZS 3000 for additional mechanical protection requirements.

This additional mechanical protection shall:

1. Be placed not more than 75mm above the wiring system.
2. Be not less than 150mm wide.
3. Overlap the system by at least 40mm on each side.
4. Consist of one or a combination of the following :
 - Precast concrete slabs having a thickness not less than 40mm and a classification of not less than grade 20 in accordance with AS 3600 or NZS 3104
 - Concrete slabs cast on-site having a thickness of not less than 100mm
 - A continuous concrete pour having a thickness of not less than 75mm
 - Fibrous cement slabs having a thickness of not less than 12mm
 - Bricks manufactured specifically for the protection of electric cables
 - Polymeric cable cover strip complying with AS 4702
 - Other materials that offer the same degree of protection afforded by the materials in above items.

Fixing

Where conduits are to be surface mounted, ensure you secure it to the building fabric with the correct size saddles or conduit clips using zinc plated or stainless steel screws into wood or masonry anchors. Galvanised or stainless steel screws may be preferred in exterior or corrosive environments while galvanised nails may be used for securing saddles in most interior applications.

When conduit is being installed on a horizontal plane, it is recommended that saddles be fixed at intervals not exceeding 600mm and 1000mm in a vertical plane. Allow provision for expansion and contraction where required. (See page 17 for temperature & expansion details)

Where conduits are to be embedded in concrete the conduit should be secured from being displaced during pouring and vibrating by securing to the formwork or reinforcing.

Bending

Marley medium duty conduit can be bent in sizes 20, 25 and 32mm. This is achieved by:

1. Inserting the correct size of bending spring.
2. Heating the conduit by briskly rubbing the area to be bent with a piece of cloth.
3. It is advisable to bend slightly beyond the angle required and then ease back to the desired position. This relieves stress and reduces the tendency for the conduit to straighten after bending.


There is a risk of kinking and damage to the bending spring if the conduit is bent too fast. Having completed the bend it should not be forced backwards as this can result in damage to both the conduit and the bending spring.

The recommended minimum radius for all diameters is not less than 6 times the conduit diameter. This will result in a swept bend that is more easily formed and less likely to kink or have a reduction in bore.

In addition, reference should also be made to the cable manufacturers recommendations regarding the maximum radius that the cable in use can be bent to.

CONDUIT OD (mm) MINIMUM BEND RADIUS (mm)

CONDUIT OD (mm)	MINIMUM BEND RADIUS (mm)
20	120
25	150
32	200



There is a requirement to identify underground wiring with orange marker tape complying with AS/NZS 2648.1 laid approximately 50% of the depth of cover above the wiring system.

The above information is provided permission by Standards New Zealand under license 001143.

ENCLOSURE BOXES

Marley enclosure boxes have been developed to meet the durability and weather performance requirements of the New Zealand Building Code B2. In addition they are UV stabilised.

Features:

- Lids are fitted with nickel plated screws. They are located within the gasketed area to ensure a continuing seal.
- Supplied with neoprene washers for sealing of mounting screws.
- Lightweight compared to metal enclosures.
- Larger high lid versions include zintec gear plate.
- Machining is easy with normal tools. Punching, drilling, filing, sawing and even ultrasonic welding are easily achieved.
- Rated to IP55 when installed according to Marley recommended installation instructions.



FLEXIBLE CONDUIT

SUPA FLEXIBLE CONDUIT

Marley SUPA is manufactured from polypropylene (PP).



TEMPERATURE

It is suitable for applications where the temperature does not exceed +60°C or fall below -5°C.

WEATHER DURABILITY

It meets the requirements of the NZ Building Code Approved Document B2 Clause B2.3 for use within buildings and in wall applications.

DUTY RATING

Marley SUPA is rated as a very light duty flexible conduit.

SUPA KEY DIMENSIONS (mm)

NOMINAL OD	MEAN OD	MINIMUM ID
20	19.85	14.1
25	24.75	18.3

CABLE CARRYING CAPACITY

The following tables show examples of maximum number of cables that may be used in conduit by cable type. The number of cables does not consider the effects the grouping of cables may have on temperature rise, voltage drop or current carrying capacity and reference should be made to AS/NZS 3008 for de-rating factors. This maximum number is based on short runs of conduit free of obstructions with minimal changes in direction. Where this is not the case the number of cables should be reduced or the conduit size increased to ensure that the maximum pulling tension is not exceeded.

GUIDE TO THE MAXIMUM NUMBER OF SINGLE-CORE SHEATHED CABLES INSTALLED IN FLEXIBLE CONDUIT

CABLE SIZE (mm²)

SUPA FLEXIBLE CONDUIT

	20	25	32	40
PVC/PVC V90				
1	4	7	14	23
1.5	3	6	11	19
2.5	2	4	8	14
4	1	3	6	10
6	1	2	5	8
10	1	1	3	5
16	1	1	2	4



CONDUIT SYSTEMS TECHNICAL INFORMATION

GUIDE TO THE MAXIMUM NUMBER OF TWO-CORE AND EARTH SHEATHED CABLES INSTALLED IN FLEXIBLE CONDUIT

CABLE SIZE
(mm²)

SUPA FLEXIBLE CONDUIT

PVC/PVC V90	20	25	32	40
1.5	1	1	1	3
2.5	0	1	1	3
4	0	1	1	2
6	0	0	1	1
PVC/PVC V75				
10	0	0	1	1
16	0	0	0	1
25	0	0	0	1
PVC/PVC V90 FLAT				
1	1	2	4	7
1.5	1	2	4	7
2.5	1	1	3	5
4	0	1	1	3
6	0	1	1	3
10	0	1	1	1
16	0	0	1	1

GUIDE TO THE MAXIMUM NUMBER OF FOUR-CORE AND EARTH SHEATHED CABLES INSTALLED IN CONDUIT

CABLE SIZE
(mm²)

SUPA FLEXIBLE CONDUIT

PVC/PVC V90	20	25	32	40
1.5	0	1	1	2
2.5	0	0	1	1
4	0	0	1	1
6	0	0	1	1

INSTALLATION

Marley SUPA is designed for use only in above ground applications.

Fixing

Where conduits are to be surface mounted, secure to the building fabric with the correct size saddles or conduit clips using zinc plated or stainless steel screws into wood or masonry anchors. Galvanised or stainless steel screws may be preferred in exterior or corrosive environments while galvanised nails may be used for securing saddles in most interior applications.

Where it is being used in a horizontal plane it is recommend that saddles be fixed at intervals not exceeding 500mm and 1000mm in a vertical plane. Allow provision for expansion and contraction where required.

Joining

Marley SUPA cannot be joined with PVC solvent cement. Use a conduit gland, plain to screw adaptor, or specialised silicon.

EASI FLEXIBLE CONDUIT

Marley EASI flexible conduit is manufactured from unplasticised polyvinyl chloride (uPVC).



TEMPERATURE

Marley EASI is suitable for applications where the temperature does not exceed +60°C or fall below -5°C.

WEATHER DURABILITY

It meets the requirements of the New Zealand Building Code Approved Document B2 Clause B2.3 for use within buildings and in wall applications.

DUTY RATING

Marley EASI is rated as medium duty in accordance with AS/NZS 2053.5

EASI KEY DIMENSIONS (mm)

NOMINAL OD	MEAN OD	MINIMUM ID
20	19.85	14.1
25	24.75	18.3
32	31.75	24.3
40	39.7	31.2
50	49.8	39.6

CABLE CARRYING CAPACITY

The following tables show examples of maximum number of cables that may be used in conduit by cable type. The number of cables does not consider the effects the grouping of cables may have on temperature rise, voltage drop or current carrying capacity and reference should be made to AS/NZS 3008 for de-rating factors. This maximum number is based on short runs of conduit free of obstructions with minimal changes in direction. Where this is not the case the number of cables should be reduced or the conduit size increased to ensure that the maximum pulling tension is not exceeded.

GUIDE TO THE MAXIMUM NUMBER OF SINGLE-CORE SHEATHED CABLES INSTALLED IN FLEXIBLE CONDUIT

CABLE SIZE (mm ²)	EASI FLEXIBLE CONDUIT			
	20	25	32	40
PVC/PVC V90				
1	4	7	14	23
1.5	3	6	11	19
2.5	2	4	8	14
4	1	3	6	10
6	1	2	5	8
10	1	1	3	5
16	1	1	2	4

GUIDE TO THE MAXIMUM NUMBER OF TWO-CORE AND EARTH SHEATHED CABLES INSTALLED IN FLEXIBLE CONDUIT

CABLE SIZE (mm ²)	EASI FLEXIBLE CONDUIT			
	20	25	32	40
PVC/PVC V90				
1.5	1	1	1	3
2.5	0	1	1	3
4	0	1	1	2
6	0	0	1	1
PVC/PVC V75				
10	0	0	1	1
16	0	0	0	1
25	0	0	0	1
PVC/PVC V90 FLAT				
1	1	2	4	7
1.5	1	2	4	7
2.5	1	1	3	5
4	0	1	1	3
6	0	1	1	3
10	0	1	1	1
16	0	0	1	1

GUIDE TO THE MAXIMUM NUMBER OF FOUR-CORE AND EARTH SHEATHED CABLES INSTALLED IN CONDUIT

CABLE SIZE (mm ²)	EASI FLEXIBLE CONDUIT			
	20	25	32	40
PVC/PVC V90				
1.5	0	1	1	2
2.5	0	0	1	1
4	0	0	1	1
6	0	0	1	1

INSTALLATION OF EASI FLEXIBLE CONDUIT

It is designed for use in above ground applications. Although it can be buried underground as well. Please refer to the wiring installation standard AS/NZS 3000 for guidance.

Fixing

Where conduits are to be surface mounted, secure to the building fabric with the correct size saddles or conduit clips using zinc plated or stainless steel screws into wood or masonry anchors. Galvanised or stainless steel screws may be preferred in exterior or corrosive environments while galvanized nails may be used for securing saddles in most interior applications.

Where being used in a horizontal plane it is recommend that saddles be fixed at intervals not exceeding 600mm and 1000mm in a vertical plane. Allow provision for expansion and contraction where required.

Where conduits are to be embedded in concrete the conduit should be secured from being displaced during pouring and vibrating by securing to the formwork or reinforcing.



SOLA FLEXIBLE CONDUIT

Marley SOLA flexible conduit is manufactured from unplasticised polyvinyl chloride (uPVC).



TEMPERATURE

Marley SOLA is suitable for applications where the temperature does not exceed +60°C or fall below -5°C.

WEATHER DURABILITY

It meets the requirements of the New Zealand Building Code Approved Document B2 Clause B2.3 for use within buildings and in wall applications. Marley SOLA conduit is suitable for external use.

DUTY RATING

Marley SOLA is rated heavy duty in accordance with AS/NZS 2053.5 and is suitable for use in photovoltaic installations in accordance with AS/NZS 5033.

SOLA KEY DIMENSIONS (mm)

NOMINAL OD	MEAN OD	MINIMUM ID
20	19.85	12.7
25	24.75	16.5
32	31.75	22.0

INSTALLATION OF SOLA FLEXIBLE CONDUIT


It is designed for use in above ground applications. Although it can be buried underground as well. Please refer to the wiring installation standard AS/NZS 3000 for guidance.

Fixing

Where conduits are to be surface mounted, secure to the building fabric with the correct size saddles or conduit clips using zinc plated or stainless steel screws into wood or masonry anchors. Galvanised or stainless steel screws may be preferred in exterior or corrosive environments while galvanized nails may be used for securing saddles in most interior applications.

Where being used in a horizontal plane it is recommend that saddles be fixed at intervals not exceeding 600mm and 1000mm in a vertical plane. Allow provision for expansion and contraction where required.

Where conduits are to be embedded in concrete the conduit should be secured from being displaced during pouring and vibrating by securing to the formwork or reinforcing.



MINI & MAXI TRUNKING

Marley trunking and fittings are manufactured from uPVC and are manufactured in accordance with AS/NZS 4296 Cable Trunking Systems.

LIDS

Marley trunking features double-lock clip tops for security and accessibility.

To remove the lid; start with a peeling action from one end. Where lids are butted together, carefully insert a screw driver blade to enable an initial start to be made. Attempts to remove the lid in one motion along its length or forcing it with a tool under the edge will fail to remove the lid and may damage the edge of the trunking.

WEATHER DURABILITY

The grey and white Marley uPVC trunking range contains titanium dioxide to provide high UV performance.

N.B. Brown Marley trunking is designed for indoor use.

N.B. Grey Marley maxi trunking has a moderate UV performance.

Marley trunking may be painted using acrylic paints which will enhance the long term weatherability when installed outside.

INSTALLATION OF TRUNKING

All installation should be in accordance with the Electrical Regulations and AS/NZS 3000 Wiring Rules.

The following is a guide only:

1. When planning the route to be taken, consider drops to sockets, switches and other fittings.
2. Where angles and tees are required the trunking base ends should be mitre cut at 45° to provide a neat join.

3. Fix the main body of the trunking by drilling through the base and screwing into position with flathead wood or metal screws. Oversize holes should be drilled to allow for expansion/contraction and large washers used under the screw to provide suitable support.
4. Fixings should be at maximum 500mm centres for mini trunking and 1000mm centres for maxi trunking. At low levels where trunking may be liable to impact or for uneven surfaces this should be reduced to 300mm centres.
5. Once the base has been fixed the wiring can then be installed (hold in place by using short offcuts of lid).
6. Cut lids 10mm shorter where fittings are to be used to allow fitting to snap over base.
7. Once the wiring is in place, snap the lid into place by starting at one end, applying even pressure and work along the length (removing temporary wire supports) as you go. Then snap on lids of fittings.
8. Allowances should be made for expansion/contraction. Do not push trunking hard against fittings. Allow a 0.6mm gap every 10 metres for every 1°C rise in temperature.

As per AS/NZS 3000* part 3.10.3.9 Cable trunking installations shall comply with the following:

- a) Covers shall be able to be opened, where practicable.
- b) Covers shall be continuous when passing through walls or floors.
- c) Cable trunking shall be accessible through its entire length.
- d) Cables installed in a trunking shall not rely on any readily removable cover for support.
- e) Non-hygroscopic trunking shall be used to enclose insulated, unsheathed conductors.
- f) Live parts of accessories mounted on cable trunking shall be arranged so that basic protection is provided, in accordance with Clause 1.5.4.



CABLE DUCT

Marley cable duct is manufactured for the conveyance and protection of electrical, communication and fibre optic cables. It is available as either a rigid or continuous duct and is primarily intended for buried applications.

Electrical duct is coloured orange and communication duct is green, salmon or red.

Some of the communication duct is specifically manufactured to meet Chorus NZ Ltd specifications and Chorus have stated that Chorus branded product may only be sold to a "Chorus approved installer or their approved subcontractor" for use in Chorus NZ projects. This product is typically green in colour.

RIGID DUCT

Rigid duct is manufactured from high quality uPVC and is available in 6 metre lengths with a socket on one end. The standard method of joining the duct is by solvent cement to provide leak free joints – refer to page 27 for the procedure. Chorus duct in 50mm and 110mm are supplied with a rubber ring jointing system.

Sizes 32, 40, 50 and 65 mm are manufactured to the outside diameters of AS/NZS 1260 with 80, 100 and 150 mm manufactured to the outside diameters of AS/NZS 2053.

RIGID DUCT MINIMUM CROSS-SECTIONAL AREA (mm²)

NOMINAL SIZE	MEAN OD (mm)	AREA	AREA	AREA
32	36.2 – 36.5	799		
40	42.8 – 43.1	1152		
50	55.7 – 56.0	2019		
65	68.7 – 69.1	3147		
80	82.3 – 82.7	4621		
100	110.0 – 110.4	8366	7853	7388
150	160.0 – 160.5	18292	16693	15700

	Light Duty		Medium Duty
	Very Light Duty		Heavy Duty

Rigid duct is intended for buried application by open trenching and it is important that all safety requirements are in place when the duct is being installed. Refer page 2.

Heavy duty and medium duty Power Duct may be used in a Category A or B underground wiring system as defined in clause 3.11.3 of AS/NZS 3000 as appropriate. For those projects utilising a specific design, Marley have a range of different duty ratings.

For a Category A system heavy duty ducting may be used without further protection and for Category B systems medium duty ducting may be used with additional mechanical protection.

This protection may be:

- Precast concrete slabs having a thickness of no less than 40mm and a classification of not less than grade 20 in accordance with AS 3600 or NZS 3104
- Concrete slabs cast on site with a thickness no less than 100mm
- A continuous concrete pour having a minimum thickness of 75mm
- Fibrous cement slabs having a minimum thickness of 12mm
- Bricks manufactured specifically for the protection of electric cables
- Polymeric cable cover strip complying with AS 4702

This protection shall be:

- Placed no more than 75mm above the wiring system
- Not less than 150mm wide
- Overlap the wiring system by at least 40mm on each side

The minimum depth of cover required for Category A and B systems is as per Table A below:

LOCATION OF WIRING SYSTEM	COVERING ON GROUND SURFACE	DEPTH OF COVER
In a building	Poured concrete >75mm	0mm (directly below)
External to a building	Poured concrete >75mm	300mm
Within or external to a building	No surface covering or < 75mm of concrete	500mm

Note: The depth of cover applies to the upper surface of the ground or the bottom of any concrete laid on the surface and either the top of the wiring system or the top of the additional mechanical protection of Category B systems.

Although the pipe is coloured orange there is still a requirement to place orange marker tape complying with AS/NZS 2648.1 approximately 50% of the depth of cover above the wiring system.

It is recommended that the burial depths above also be applied to communication systems.



CONTINUOUS DUCT

Continuous duct is manufactured to the dimensions of AS/NZS 4130. It is made from high quality polyethylene and is available in lengths from 50 metres to 1000 metres depending upon the diameter of the pipe. This product is suitable for directional drilling and open trenches.

The duct is available for Power and Communication installations.

Where the pipe is directional drilled, it is unlikely that any additional mechanical protection will be provided and therefore the system should be a Category A system and therefore heavy duty duct should be used. The covers depths are detailed in Table A above.

Lengths of duct may be joined by the use of Marley electrofusion fittings or compression fittings. Instructions for the use of these fittings can be found at www.marley.co.nz – search: Philmac Fittings and/or Friatec Fittings.

SUB-DUCT MINIMUM CROSS-SECTIONAL AREA (mm)²

NOMINAL SIZE	MEAN OD (mm)	SDR	CROSS SECTIONAL AREA
20	20.0 - 20.3	11	125
25	25.0 - 25.3	11	200
32	32.0 - 32.3	13.6	330

POWER AND COMMUNICATION DUCT MINIMUM CROSS-SECTIONAL AREA (mm²)

NOMINAL SIZE	MEAN OD (mm)	SDR	AREA
40	40.0 - 40.4	17	929
50	50.0 - 50.4	17	1465
63	63.0 - 63.6	17	2324
90	90.0 - 90.9	17	4802
110	110.0 - 111.0	17	7147
125	125.0 - 126.1	17	9227
140	140.0 - 141.2	17	11308
160	160.0 - 161.5	17	15128

Medium Duty
 Heavy Duty

TOWING LOADS

Continuous duct is predominantly installed using ‘no dig’ methods which require the duct to be pulled through the ground. This requires a pulling load to be applied to the duct in order to draw it forward and the load requirement will be influenced by; the length and straightness of the run, the friction between the pipe, and the surrounding ground and diameter of the pipe.

Where possible, the minimum towing load to achieve the installation should be used and in no case should the loads in the following table be exceeded. Exceeding these loads may result in a reduction of the diameter and wall thickness of the duct.

When slip lining it is recommended that for long strings, a pipe relaxation period of at least 24hours is allowed before grouting or making permanent tie-in joints.

Where a pipe of a greater wall thickness (lower SDR) is being used to those shown in the table then the same guidelines can safely be used.

MARLEY PIPE SIZE AND TOWING LOADS

PIPE SIZE	SDR	20°C TONNES
20	11	0.08*
25	11	0.12*
32	13.6	0.27*
40	17	0.22
50	17	0.32
63	17	0.5
90	17	1.1
110	17	1.6
125	17	2.1
140	17	2.5
160	17	3.4

* It is recommended that the smaller diameters be pulled by hand.



*Provided permission by Standards New Zealand under license 001143.

The above information is provided permission by Standards New Zealand under license 001143.

SOLVENT JOINTING PROCEDURES

Assembly of solvent joints is easy, reliable and efficient as long as the following simple procedure is followed.

SAFETY PRECAUTIONS WITH SOLVENT WELD JOINTING

- Make sure there is adequate ventilation. Forced ventilation may be necessary inside buildings, in confined trenches and manholes.
- Solvent cement and priming fluids are highly flammable. Store them in a cool place away from heat, flames and sparks. Do not smoke while using them.
- Keep the containers tightly sealed when not in use.
- Do not add thinners or solvents to Marley Gold or Marley Clear Solvent Cement or Marley Joint Primer.
- Do not use old solvent cement that has become jelly like or expired.
- Do not use dirty or contaminated brushes or rags.

Solvent cement spilt onto skin should be washed off immediately with soap and water. Should solvent cement affect the eyes, flush with cool clean water for at least 15 minutes. If solvent cement or primer is swallowed, induce vomiting. Safety and First Aid instructions on the container should be followed.

Wash hands thoroughly after use.

SPECIAL CONSIDERATIONS

Workmanship and correct procedures are essential for solvent joints if water tightness and durability are to be assured. Solvent jointing should only be carried out in dry conditions above 5°C, by appropriately trained personnel.

Solvent cement jointing is a welding not a gluing process. Priming fluid and Marley Solvent Cements soften the surfaces, so when they are brought together the two PVC surfaces bond together.

It is important that the spigot provides an interference fit in the socket. Do not attempt to make a joint that does not achieve an interference fit when dry. The actual area of contact between the spigot and the socket may only be a few millimetres. The spigot end must be square to make a good joint. Before proceeding, make sure that the spigots and sockets are not cracked or damaged.

To make successful solvent weld joints on PVC pipe, the following procedure is recommended:


- Minimise the number of joints.
- Introduce no deflections or strain on pipe fittings or joints.
- Check pipes have not been damaged during transit.
- Cut the pipes with only a fine tooth hack saw. Ensure the pipe spigot is cut square, taking care not to chip or crack the pipe. Remove all burrs from the inside. Make a 15° chamfer to the outside of the cut end of the pipe to remove any other burrs.
- Mark the insertion depth on the pipe spigot. The insertion depth is equivalent to the depth of the corresponding joint socket. The pipe should be marked with a soft pencil or felt pen which does not damage the pipe.
- Dry assemble all pipes and joints. Check that all joints have a full interference fit. Interference fit means that the pipe spigot should not be able to fully penetrate the socket up to the insertion mark without force.
- Mark the pipe and spigot for alignment by drawing a horizontal line across the joint with a soft pencil or felt pen.
- Ensure the pipe spigot and socket are free of dust, dirt and grease, by wiping with a clean cloth clipped in methylated

spirits or Marly primer.

- Coat the socket and the spigot sparingly with either Marley Gold or Marley Clear Solvent Cement.
- Immediately push together firmly to evenly spread the solvent cement and wipe off any excess Solvent Cement. Do not handle the joint for approximately 5 minutes and allow 10 hours of drying time before any rough handling or testing.

RUBBER RING JOINTING

Check the socket, spigot and rubber ring are clean and that the ring is sitting in the socket so that the flap is facing into the pipe. Apply Marley jointing lubricant to the spigot of the pipe and ensuring the pipe is in line with the socket push the pipe into the socket.



MATERIAL PROPERTIES

Marley supply a wide range of products in; uPVC, polypropylene and polyethylene. Please see table below for more information on the properties of these materials.

PROPERTY	UNITS	uPVC	POLYPROPYLENE	POLYETHYLENE
CO-EFFICIENT OF THERMAL EXPANSION	X 10 ⁻⁵	6	17	17
SPECIFIC HEAT	JK ⁻¹ kg ⁻¹	1250	1800	1900
THERMAL CONDUCTIVITY	w/m °C	.16	.22	.45
FLAMMABILITY		Self extinguishing	Flame propagating	Flame propagating
SPECIFIC GRAVITY		1.46	.96	.95
WATER ABSORPTION	%	0.5	<0.1	<0.1
VICAT SOFTENING TEMPERATURE	°C	80	114	120
MAX SERVICE TEMPERATURE	°C	60	60	60
MINIMUM SERVICE TEMPERATURE	°C	-15	0	0
DIELECTRIC STRENGTH	kV/mm	14	30	22
VOLUME RESISTIVITY	ΩM	1.2 x 10 ¹⁴	>10 ¹⁴	>10 ¹³
SURFACE RESISTIVITY	ΩM	10 ¹⁵	>10 ¹⁶	>10 ¹⁵
DIELECTRIC CONSTANT	1MHz	2.7	2.2	2.3
DISSIPATION FACTOR	1MHz	.025	.0004	.0003

Note: Above values are indicative only.

 FOLLOW US @MARLEYNEWZEALAND

DISCLAIMER

This technical catalogue has been compiled by Marley New Zealand Limited ("The Company") to promote better understanding of the technical aspects of the Company's products to assist users in obtaining from them the best possible performance. The technical catalogue is supplied subject to acknowledgment of the following conditions:

The technical catalogue is protected by Copyright and may not be copied or reproduced in any form or by any means in whole or in part without prior consent in writing by the Company. Product specifications, usage data and advisory information may change from time to time with advances in research and field experience. The Company reserves the right to make such changes at any time without notice. Correct usage of the Company's products involve engineering judgements which cannot be properly made without full knowledge of all the conditions pertaining to each specific installation. The Company expressly disclaims all and any liability to any person whether supplied with this publication or not in respect of anything and of the consequences of anything done or omitted to be done by any such person in reliance whether whole or partial upon the whole or any part of the contents of this publication. No offer to trade, nor any conditions of trading, are expressed or implied by the issue or content of this manual. Nothing herein shall override the Company's Conditions of Sale, which may be obtained from the Registered Office or any Sales Office of the Company. This technical catalogue is and shall remain the property of the Company, and shall be surrendered on demand to the Company. Actual colours may vary slightly from those shown. For a more accurate colour comparison, please request a product sample.

MAR2437 November 2016

OUR PARTNERS



For more information: **0800 MARLEY (0800 627539)**

www.marley.co.nz

an *Aliaxis* company

Cable Management

